

## COMPRESSOR DATA SHEET

Federal Uniform Test Method for Certain Air Compressors Not Applicable

Rotary Compressor: Variable Frequency Drive

MODEL DATA - FOR COMPRESSED AIR											
1	1 Manufacturer: Kaishan Compressor USA										
	Model Number: K	ROF-150-125 VSD		Date:	05/08/24						
2	X Air-cooled	Water-cooled		Type:	Screw						
	Lubricated		# of Stages:	2							
3*	Full Load Operating Pr	essure b	125	psig <sup>b</sup>							
4	Drive Motor Nominal Rating		150	hp							
5	Drive Motor Nominal Efficiency		95.4	percent							
6	Fan Motor Nominal Ra	Motor Nominal Rating (if applicable)		hp							
7	Fan Motor Nominal Ef	Notor Nominal Efficiency		percent							
	Input Power (kW)		Capacity (acfm) <sup>a,d</sup>	Specific Power (kW/100 acfm) <sup>d</sup>							
	136.3		681	20.01							
8*	120.8		612	19.74							
	108.4		541	20.04							
	96.0		471	20.38							
	83.6		400	20.90							
9*	Total Package Input Power at Zero Flow c, d		0.0	kW							
10	Isentropic Efficiency		73.28	%							
11	35.00 Specific Power (RW/100 A CEM)  30.00 - 25.00 - 20.00 - 2	Note: Graph is only a vi Note: Y-Axis Scale, 10 to 35,	300 400 500  Capacity (ACFM)  sual representation of the data in +5kW/100acfm increments if nece 0 to 25% over maximum capacity	Section 8	700 800						

\*For models that are tested in the CAGI Performance Verification Program, these items are verified by the third party administrator Consult CAGI website for a list of participants in the third party verification program: <a href="www.cagi.org">www.cagi.org</a>

NOTES



- a. Measured at the discharge terminal point of the compressor package in accordance with ISO 1217, Annex E;
   ACFM is actual cubic feet per minute at inlet conditions.
- b. The operating pressure at which the Capacity (Item 8) and Electrical Consumption (Item 8) were measured for this data sheet.
- c. No Load Power. In accordance with ISO 1217, Annex E, if measurement of no load power equals less than 1%,
- manufacturer may state "not significant" or "0" on the test report.
  d. Tolerance is specified in ISO 1217, Annex E, as shown in table below:

NOTE: The terms "power" and "energy" are synonymous for purposes of this document.

iviember

Volume Flow Rate at specified conditions		Volume Flow Rate	Specific Energy Consumption	Zero Flow Power
$\underline{\mathbf{m}}^3 / \underline{\mathbf{min}}$	ft <sup>3</sup> / min	%	%	%
Below 0.5	Below 17.6	+/- 7	+/- 8	
0.5 to 1.5	17.6 to 53	+/- 6	+/- 7	+/- 10%
1.5 to 15	53 to 529.7	+/- 5	+/- 6	17- 1070
Above 15	Above 529.7	+/- 4	+/- 5	

ROT 031.2

12/19 R3

This form was developed by the Compressed Air and Gas Institute for the use of its members participating in the PVP. CAGI has not independently verified the reported data.