

COMPRESSOR DATA SHEET

Federal Uniform Test Method for Certain Air Compressors Not Applicable

Rotary Compressor: Variable Frequency Drive

MODEL DATA - FOR COMPRESSED AIR										
1	Manufacturer: Kaishan Compressor USA									
	Model Number:			Date:	(05/08/24				
2	X Air-co	ooled	Water-cooled			Type:		Screw		
	Lubric	ated X	Oil Free		;	# of Stages:		2		
3*	Full Load Operating Pressure ^b			15	0	psig				
4	Drive Motor Nominal Rating			15	0	hp				
5	Drive Motor Nominal Efficiency			95.	4	percent				
6	Fan Motor Nom	Fan Motor Nominal Rating (if applicable)			3.5	hp				
7	Fan Motor Nom	Fan Motor Nominal Efficiency			6	percent				
8*	Input Power (kW)			Capacity (Capacity (acfm) ^{a,d}		Specific Power (kW/100 acfm) ^d			
	136.3			60:	2		22.64			
	120.8			54	1		22.33			
	108.4			47	9	22.63				
	96.0			41	416		23.08			
	83.6			35	353 23		23.68			
9*	Total Package Input Power at Zero Flow c, d			0.0		kW				
10	Isentropic Effic	Isentropic Efficiency			62	%				
11	Specific Power (KW/100 ACFM)	35.00 30.00 25.00 20.00 15.00 0	100 200 Note: Graph is only a ote: Y-Axis Scale, 10 to 3 X-Axis Scale		rements if neces:		600	700		

*For models that are tested in the CAGI Performance Verification Program, these items are verified by the third party administrator Consult CAGI website for a list of participants in the third party verification program: www.cagi.org

NOTES



- a. Measured at the discharge terminal point of the compressor package in accordance with ISO 1217, Annex E;
 ACFM is actual cubic feet per minute at inlet conditions.
- b. The operating pressure at which the Capacity (Item 8) and Electrical Consumption (Item 8) were measured for this data sheet.
- c. No Load Power. In accordance with ISO 1217, Annex E, if measurement of no load power equals less than 1%,
- manufacturer may state "not significant" or "0" on the test report.
 d. Tolerance is specified in ISO 1217, Annex E, as shown in table below:

NOTE: The terms "power" and "energy" are synonymous for purposes of this document.

	olume Flow Rate pecified conditions	Volume Flow Rate	Specific Energy Consumption	Zero Flow Power
$\underline{m}^3 / \underline{min}$	ft ³ / min	%	%	%
Below 0.5	Below 17.6	+/- 7	+/- 8	
0.5 to 1.5	17.6 to 53	+/- 6	+/- 7	+/- 10%
1.5 to 15	53 to 529.7	+/- 5	+/- 6	17- 1070
Above 15	Above 529.7	+/- 4	+/- 5	

ROT 031.2 12/19 R3

This form was developed by the Compressed Air and Gas Institute for the use of its members participating in the PVP. CAGI has not independently verified the reported data.