

## COMPRESSOR DATA SHEET

Federal Uniform Test Method for Certain Air Compressors Not Applicable

Rotary Compressor: Variable Frequency Drive

MODEL DATA - FOR COMPRESSED AIR								
1	Manufacturer: Kaishan Compressor USA							
	Model Number: KROF-200-125 VSD			Date:	04/12/24			
2	X Air-cooled	Water-cooled		Type:	screw			
	Lubricated X Oil Free			# of Stages:	2			
3*	Full Load Operating Press			psig <sup>b</sup>				
4	Drive Motor Nominal Rating		200	hp				
5	Drive Motor Nominal Efficiency		95.4	percent				
6	Fan Motor Nominal Ratin	Fan Motor Nominal Rating (if applicable)		hp				
7	Fan Motor Nominal Effici	ency	71.6	percent				
	Input Power (kW)		Capacity (acfm) <sup>a,d</sup>	Specific Power (kW/100 acfm) <sup>d</sup>				
	176.0		892	19.73				
8*	155.9		802	19.44				
	139.9		709	19.73				
	124.0		616	20.13				
	108.0		524	20.61				
9*	Total Package Input Power at Zero Flow c, d		0.0 74.75	kW				
10	Isentropic Efficiency	Isentropic Efficiency		%				
11	35.00 30.00 30.00 25.00 25.00 20.00 15.00 0	Note: Graph is only a vis Note: Y-Axis Scale, 10 to 35,	400 500 600  Capacity (ACFM)  sual representation of the data in: + 5kW/100acfm increments if neces 0 to 25% over maximum capacity		900 1000			

\*For models that are tested in the CAGI Performance Verification Program, these items are verified by the third party administrator Consult CAGI website for a list of participants in the third party verification program: <a href="www.cagi.org">www.cagi.org</a>





wember

- a. Measured at the discharge terminal point of the compressor package in accordance with ISO 1217, Annex E;
   ACFM is actual cubic feet per minute at inlet conditions.
- b. The operating pressure at which the Capacity (Item 8) and Electrical Consumption (Item 8) were measured for this data sheet.
- c. No Load Power. In accordance with ISO 1217, Annex E, if measurement of no load power equals less than 1%,
- manufacturer may state "not significant" or "0" on the test report.
  d. Tolerance is specified in ISO 1217, Annex E, as shown in table below:

NOTE: The terms "power" and "energy" are synonymous for purposes of this document.

Volume Flow Rate at specified conditions		Volume Flow Rate Specific Energy Consumption		Zero Flow Power
$\underline{\mathbf{m}^3 / \mathbf{min}}$	ft <sup>3</sup> / min	%	%	%
Below 0.5	Below 17.6	+/- 7	+/- 8	
0.5 to 1.5	17.6 to 53	+/- 6	+/- 7	+/- 10%
1.5 to 15	53 to 529.7	+/- 5	+/- 6	17- 1070
Above 15	Above 529.7	+/- 4	+/- 5	

ROT 031.2 12/19 R3

This form was developed by the Compressed Air and Gas Institute for the use of its members participating in the PVP. CAGI has not independently verified the reported data.