

COMPRESSOR DATA SHEET

Federal Uniform Test Method for Certain Air Compressors Not Applicable

Rotary Compressor: Variable Frequency Drive

MODEL DATA - FOR COMPRESSED AIR									
1	Manufacturer: Kaishan Compressor USA								
	Model Number: KRO	F-200-150 VSD		Date:	05/08/24				
2	Air-cooled X	Water-cooled		Type:	Screw				
	Lubricated X		# of Stages:	2					
3*	Full Load Operating Pressure b		100	psig ^b					
4	Drive Motor Nominal Rating		200	hp					
5	Drive Motor Nominal Efficiency		95.4	percent					
6	Fan Motor Nominal Rating (if applicable)		0.5	hp					
7	Fan Motor Nominal Efficiency		69.5	percent					
	Input Power (kW)		Capacity (acfm) ^{a,d}	Specific Power (kW/100 acfm) ^d					
	172.0		823	20.90					
8*	152.4		740	20.59					
	136.7		654	20.90					
	121.1		569 21.28		21.28				
	105.4		483	21.82					
9*	Total Package Input Power at Zero Flow c, d		0.0	kW					
10	Isentropic Efficiency		62.22	%					
11	Sentropic Efficiency 62.22 %								

*For models that are tested in the CAGI Performance Verification Program, these items are verified by the third party administrator Consult CAGI website for a list of participants in the third party verification program: www.cagi.org





wember

- a. Measured at the discharge terminal point of the compressor package in accordance with ISO 1217, Annex E;
 ACFM is actual cubic feet per minute at inlet conditions.
- b. The operating pressure at which the Capacity (Item 8) and Electrical Consumption (Item 8) were measured for this data sheet.
- c. No Load Power. In accordance with ISO 1217, Annex E, if measurement of no load power equals less than 1%, manufacturer may state "not significant" or "0" on the test report.
- d. Tolerance is specified in ISO 1217, Annex E, as shown in table below:

NOTE: The terms "power" and "energy" are synonymous for purposes of this document.

Volume Flow Rate at specified conditions		Volume Flow Rate	Specific Energy Consumption	Zero Flow Power
$\underline{\mathbf{m}}^3 / \underline{\mathbf{min}}$	ft ³ / min	%	%	%
Below 0.5	Below 17.6	+/- 7	+/- 8	
0.5 to 1.5	17.6 to 53	+/- 6	+/- 7	+/- 10%
1.5 to 15	53 to 529.7	+/- 5	+/- 6	1/- 10/0
Above 15	Above 529.7	+/- 4	+/- 5	

ROT 031.2 12/19 R3

This form was developed by the Compressed Air and Gas Institute for the use of its members participating in the PVP. CAGI has not independently verified the reported data.