COMPRESSOR DATA SHEET



In Accordance With Federal Uniform Test Method for Certain Lubricated Air Compressors

Rotary Compressor: Variable Frequency Drive

		MOI	DEL DATA - FO	OR COMPRESSED	AIR					
1	Manufacturer: Kaishan Compressor USA									
	Model Number	r: KRSD	-100-115 VSD Date:		Date:	06/08/23				
2	X Air-o	cooled	Water-cooled		Type:	Screw				
					# of Stages:	1				
3*	Full Load Operating Pressure b			115	<u> </u>	psig ^b				
4	Drive Motor Nominal Rating			100		hp				
5	Drive Motor Nominal Efficiency			94.1		percent				
6	Fan Motor Nominal Rating (if applicable)			3	hp					
7	Fan Motor Nominal Efficiency			89.5	percent					
	Input Power (kW)			Capacity (acfm) ^{a,d}	Specific Power (kW/100 acfm) ^d					
	96.8			499	1	19.40				
8*	75.9			392	1	19.36				
	66.0			343	1	19.24				
	48.3			245	1	19.71				
	41.5			196	2	21.17				
9*	Total Package Input Power at Zero Flow c, d			0.0		kW				
10	Isentropic Efficiency			72.87		%				
11	Spedfic Power (kW/100 A/CFM)	35.00								
		25.00								
		15.00	50 75 100 125 150 17.	5 200 225 250 275 300 325	350 375 400 425	450 475 500 525				
	Capacity (ACFM) Note: Graph is only a visual representation of the data in Section 8 Note: Y-Axis Scale, 10 to 35, + 5kW/100acfm increments if necessary above 35 X-Axis Scale, 0 to 25% over maximum capacity									

*For models that are tested in the CAGI Performance Verification Program, these items are verified by the third party administrator Consult CAGI website for a list of participants in the third party verification program: www.cagi.org

NOTES:



- a. Measured at the discharge terminal point of the compressor package in accordance with ISO 1217, Annex E;
 ACFM is actual cubic feet per minute at inlet conditions.
- b. The operating pressure at which the Capacity (Item 8) and Electrical Consumption (Item 8) were measured for this data sheet.
- c. No Load Power. In accordance with ISO 1217, Annex E, if measurement of no load power equals less than 1%, manufacturer may state "not significant" or "0" on the test report.
- d. Tolerance is specified in ISO 1217, Annex E, as shown in table below:
 NOTE: The terms "power" and "energy" are synonymous for purposes of this document.

Member

	olume Flow Rate secified conditions	Volume Flow Rate	Specific Energy Consumption	No Load / Zero Flow Power
$\underline{\mathbf{m}}^3 / \underline{\mathbf{min}}$	ft ³ / min	%	%	%
Below 0.5	Below 17.6	+/- 7	+/- 8	
0.5 to 1.5	17.6 to 53	+/- 6	+/- 7	+/- 10%
1.5 to 15	53 to 529.7	+/- 5	+/- 6	17 1070
Above 15	Above 529.7	+/- 4	+/- 5	

ROT 031.1