COMPRESSOR DATA SHEET



In Accordance With Federal Uniform Test Method for Certain Lubricated Air Compressors

Rotary Compressor: Variable Frequency Drive

MODEL DATA - FOR COMPRESSED AIR									
1	Manufacturer:	Kaish	an Compressor l	JSA					
	Model Number: KRSD-100-125 VSD				Date:	06/08/23			
2	X Air-cooled Water-cooled			Type: Screw		Screw			
		_			# of Stages:	1			
3*	Full Load Operating Pressure b			125	" or buges.	psig ^b			
4	Drive Motor Nominal Rating			100	hp				
5	Drive Motor Nominal Efficiency			94.1	percent				
6	Fan Motor Nominal Rating (if applicable)			3	hp				
7	Fan Motor Nominal Efficiency			89.5	percent				
	Input Power (kW)			Capacity (acfm) ^{a,d}	Specific Power (kW/100 acfm) ^d				
	97.1			497	1	19.54			
8*	75.5			376	2	20.08			
	66.8			329	2	20.30			
	48.6			235	2	20.68			
	43.8		<u> </u>	188	23.30				
9*	Total Package Input Power at Zero Flow c, d			0.0	kW				
10	Isentropic Efficien	Isentropic Efficiency			%				
	35.0	ж то							
	30.0)0							
	Specific Power (KW/100 A CFM)	00							
11	Speci (kW/1)0							
	15.0	00							
	10.0	0 25 50 75 100 125 150 175 200 225 250 275 300 325 350 375 400 425 450 475 500 525							
	Capacity (ACFM) Note: Graph is only a visual representation of the data in Section 8 Note: Y-Axis Scale, 10 to 35, + 5kW/100acfm increments if necessary above 35 X-Axis Scale, 0 to 25% over maximum capacity								

*For models that are tested in the CAGI Performance Verification Program, these items are verified by the third party administrator Consult CAGI website for a list of participants in the third party verification program: www.cagi.org

NOTES:



- a. Measured at the discharge terminal point of the compressor package in accordance with ISO 1217, Annex E;
 ACFM is actual cubic feet per minute at inlet conditions.
- b. The operating pressure at which the Capacity (Item 8) and Electrical Consumption (Item 8) were measured for this data sheet.
- c. No Load Power. In accordance with ISO 1217, Annex E, if measurement of no load power equals less than 1%, manufacturer may state "not significant" or "0" on the test report.
- d. Tolerance is specified in ISO 1217, Annex E, as shown in table below:
 NOTE: The terms "power" and "energy" are synonymous for purposes of this document.

Member

Volume Flow Rate at specified conditions		Volume Flow Rate	Specific Energy Consumption	No Load / Zero Flow Power
$\underline{\mathbf{m}}^3 / \underline{\mathbf{min}}$	ft ³ / min	%	%	%
Below 0.5	Below 17.6	+/- 7	+/- 8	
0.5 to 1.5	17.6 to 53	+/- 6	+/- 7	+/- 10%
1.5 to 15	53 to 529.7	+/- 5	+/- 6	17 1070
Above 15	Above 529.7	+/- 4	+/- 5	

ROT 031.1