COMPRESSOR DATA SHEET



In Accordance With Federal Uniform Test Method for Certain Lubricated Air Compressors

Rotary Compressor: Variable Frequency Drive

| MODEL DATA - FOR COMPRESSED AIR | | | | | | | | |
|---------------------------------|---|----------------------------|--|---|-------------------|--|--|--|
| 1 | Manufacturer: Kaishan Compressor USA | | | | | | | |
| | Model Number: | KRSD-20-115 VSD | | Date: | 06/30/20 | | | |
| 2 | X Air-cooled | Water-cooled | | Type: | Screw | | | |
| | | | | # of Stages: | 1 | | | |
| 3* | Full Load Operating Pressure ^b | | 115 | | psig ^b | | | |
| 4 | Drive Motor Nominal Rating | | 20 | hp | | | | |
| 5 | Drive Motor Nominal Efficiency | | 91.5 | percent | | | | |
| 6 | Fan Motor Nominal Rating (if applicable) | | 0.33 | hp | | | | |
| 7 | Fan Motor Nominal Efficiency | | 74.8 | percent | | | | |
| | Input Power (kW) |) | Capacity (acfm) ^{a,d} | Specific Power (kW/100 acfm) ^d | | | | |
| | 16.2 | | 72 | 22.50 | | | | |
| 8* | 11.6 | | 50 | 23.20 | | | | |
| | 10.0 | | 42 | 23.81 | | | | |
| | 8.4 | | 35 | 24.00 | | | | |
| | 7.9 | | 27 | 29.26 | | | | |
| 9* | Total Package Input Power at Zero Flow c, d | | 0.0 | kW | | | | |
| 10 | Isentropic Efficiency | | 60.33 | % | | | | |
| 11 | 35.00 - 30.00 - 30.00 - 25.00 - 25.00 - 20.00 - 15.00 - | Note: Graph is only a visu | 50 Capacity (ACFM) ual representation of the data in S | | 100 | | | |
| | Note: Y-Axis Scale, 10 to 35, + 5kW/100acfm increments if necessary above 35 X-Axis Scale, 0 to 25% over maximum capacity | | | | | | | |

*For models that are tested in the CAGI Performance Verification Program, these items are verified by the third party administrator Consult CAGI website for a list of participants in the third party verification program: www.cagi.org

NOTES:



Member

- a. Measured at the discharge terminal point of the compressor package in accordance with ISO 1217, Annex E;
 ACFM is actual cubic feet per minute at inlet conditions.
- b. The operating pressure at which the Capacity (Item 8) and Electrical Consumption (Item 8) were measured for this data sheet.
- c. No Load Power. In accordance with ISO 1217, Annex E, if measurement of no load power equals less than 1%, manufacturer may state "not significant" or "0" on the test report.
- d. Tolerance is specified in ISO 1217, Annex E, as shown in table below:
 NOTE: The terms "power" and "energy" are synonymous for purposes of this document.

| Volume Flow Rate at specified conditions | | Volume Flow Rate | Specific Energy Consumption | No Load / Zero Flow Power |
|---|-----------------------|------------------|--------------------------------|---------------------------------|
| $\underline{\mathbf{m}}^3 / \underline{\mathbf{min}}$ | ft ³ / min | % | % | % |
| Below 0.5 | Below 17.6 | +/- 7 | +/- 8 | |
| 0.5 to 1.5 | 17.6 to 53 | +/- 6 | +/- 7 | +/- 10% |
| 1.5 to 15 | 53 to 529.7 | +/- 5 | +/- 6 | ., 1070 |
| Above 15 | Above 529.7 | +/- 4 | +/- 5 | |

ROT 031.1