



## COMPRESSOR DATA SHEET

Federal Uniform Test Method for Certain Air Compressors Not Applicable

Rotary Compressor: Fixed Speed

### MODEL DATA - FOR COMPRESSED AIR

1	Manufacturer:	<b>Kaishan Compressor USA</b>			
2	Model Number:	<b>KRSP-250-150</b>		Date:	<b>6/30/2020</b>
	<input type="checkbox"/> Air-cooled	<input checked="" type="checkbox"/> Water-cooled	Type:	<b>Screw</b>	
	<input type="checkbox"/> Oil-injected	<input type="checkbox"/> Oil-free	# of Stages:	<b>1</b>	
3*	Rated Capacity at Full Load Operating Pressure a, e	<b>935.0</b>	acfm <sup>a,e</sup>		
4	Full Load Operating Pressure <sup>b</sup>	<b>150</b>	psig <sup>b</sup>		
5	Maximum Full Flow Operating Pressure <sup>c</sup>	<b>150</b>	psig <sup>c</sup>		
6	Drive Motor Nominal Rating	<b>250</b>	hp		
7	Drive Motor Nominal Efficiency	<b>96.2</b>	percent		
8	Fan Motor Nominal Rating (if applicable)	<b>0.5</b>	hp		
9	Fan Motor Nominal Efficiency	<b>76.2</b>	percent		
10*	Total Package Input Power at Zero Flow <sup>e</sup>	<b>41.5</b>	kW <sup>e</sup>		
11	Total Package Input Power at Rated Capacity and Full Load Operating Pressure <sup>d</sup>	<b>191.10</b>	kW <sup>d</sup>		
12*	Specific Package Input Power at Rated Capacity and Full Load Operating Pressure <sup>e</sup>	<b>20.44</b>	kW/100 cfm <sup>e</sup>		
13	Isentropic Efficiency	<b>80.93</b>	Percent		

\*For models that are tested in the CAGI Performance Verification Program, these items are verified by the third party administrator. Consult CAGI website for a list of participants in the third party verification program: [www.cagi.org](http://www.cagi.org)

NOTES:

- a. Measured at the discharge terminal point of the compressor package in accordance with ISO 1217, Annex C; ACFM is actual cubic feet per minute at inlet conditions.
- b. The operating pressure at which the Capacity (Item 3) and Electrical Consumption (Item 11) were measured for this data sheet.
- c. Maximum pressure attainable at full flow, usually the unload pressure setting for load/no load control or the maximum pressure attainable before capacity control begins. May require additional power.
- d. Total package input power at other than reported operating points will vary with control strategy.
- e. Tolerance is specified in ISO 1217, Annex C, as shown in table below:

NOTE: The terms "power" and "energy" are synonymous for purposes of this document.

Volume Flow Rate at specified conditions		Volume Flow Rate	Specific Energy Consumption	No Load / Zero Flow Power
m <sup>3</sup> / min	ft <sup>3</sup> / min	%	%	%
Below 0.5	Below 17.6	+/- 7	+/- 8	+/- 10%
0.5 to 1.5	17.6 to 53	+/- 6	+/- 7	
1.5 to 15	53 to 529.7	+/- 5	+/- 6	
Above 15	Above 529.7	+/- 4	+/- 5	



Member

ROT 030.2