



KAISHAN In Accordance with Federal Uniform Test Method for Certain Lubricated Air Compressors

Rotary Compressor: Fixed Speed

MODEL DATA - FOR COMPRESSED AIR						
1	Manufacturer: Kaishan Compressor USA					
	Model Number: PK-7.5-150 1PH	Date:	8/1/2024			
2	X Air-cooled Water-cooled	Type:	Screw			
		# of Stages:	1			
3*	Rated Capacity at Full Load Operating Pressure a, e	22.0	acfm ^{a,e}			
4*	Full Load Operating Pressure b	150	psig ^b			
5	Maximum Full Flow Operating Pressure c	150	psig ^c			
6	Drive Motor Nominal Rating	7.5	hp			
7	Drive Motor Nominal Efficiency	88.5	percent			
8	Fan Motor Nominal Rating (if applicable)	0.13	hp			
9	Fan Motor Nominal Efficiency	83.5	percent			
10*	Total Package Input Power at Zero Flow	2.2	kW ^e			
11	Total Package Input Power at Rated Capacity and Full Load Operating Pressure ^d	7.03	kW^d			
12*	Package Specific Power at Rated Capacity and Full Load Operating Pressure ^e	31.95	kW/100 cfm ^e			
13	Isentropic Efficiency	51.76	Percent			

^{*}For models that are tested in the CAGI Performance Verification Program, these items are verified by the third party administrator.

Consult CAGI website for a list of participants in the third party verification program: www.cagi.org

NOTES:

- a. Measured at the discharge terminal point of the compressor package in accordance with ISO 1217, Annex C; ACFM is actual cubic feet per minute at inlet conditions.
- b. The operating pressure at which the Capacity (Item 3) and Electrical Consumption (Item 11) were measured for this data sheet.
- c. Maximum pressure attainable at full flow, usually the unload pressure setting for load/no load control or the maximum pressure attainable before capacity control begins. May require additional power.
- $d. \ Total\ package\ input\ power\ at\ other\ than\ reported\ operating\ points\ will\ vary\ with\ control\ strategy.$
- e. Tolerance is specified in ISO 1217, Annex C, as shown in table below:

NOTE: The terms "power" and "energy" are synonymous for purposes of this document.

U	M	u	
Compres	sed Air &	Gas Institi	ute

Member

	Volume Flow Rate at specified conditions	Volume Flow Rate	Specific Energy Consumption	No Load / Zero Flow Power	
m ³ / min	<u>ft³ / min</u>	%	%	%	
Below 0.5	Below 17.6	+/- 7	+/- 8		
0.5 to 1.5	17.6 to 53	+/- 6	+/- 7	. / 100/	
1.5 to 15	53 to 529.7	+/- 5	+/- 6	+/- 10%	
Above 15	Above 529.7	+/- 4	+/- 5		

ROT 030.1

12/19 Rev : This form was developed by the Compressed Air and Gas Institute for the use of its members participating in the PVP. CAGI has not independently verified the reported data.